


Super Nordstrom Two-Bolt Cover-Type Iron Plug Valves


Short Pattern (Gate Length)


200 CWP (13.8 bar) 400 psig (27.6 bar) Test

Figure 142 Threaded, Wrench Operated, Sizes ½ to 4 Figure 143 Flanged, Wrench Operated, Sizes 1 to 5









Size	NPS	1/2	3/4	1	11⁄4	1½	2	2 ½	3	4	5
	DN	15	20	25	32	40	50	65	80	100	125
End-to-end, threaded,	А	4.50	4.50	4.50	5.00	5.00	5.88	7.00	7.62	9.00	
Figure 142		114	114	114	127	127	149	178	194	229	
End-to-end, flanged,	, o , l B			5.50	6.50	6.50	7.00	7.50	8.00	9.00	10.00
Figure 143				140	165	165	178	191	203	229	254
Diameter of flance	C			4.3	4.6	5.0	6.0	7.0	7.5	9.0	10.0
Diameter of flange	С			109	117	127	152	178	191	229	254
Contar to ton of atom	Е	3.8	3.8	3.8	4.1	4.1	4.7	4.7	5.6	6.3	6.3
Center to top of stem	E	97	97	97	104	104	119	119	142	160	160
Center to bottom of body F	Е	1.9	1.9	1.9	2.1	2.1	2.4	2.4	3.4	4.0	4.0
	Г	48	48	48	53	53	61	61	86	102	102
Clearance required to	G	5.5	5.5	5.5	5.8	5.8	6.4	6.4	7.2	8.0	8.0
remove sealant fitting	u	140	140	140	147	147	163	163	183	203	203
Width of stem flats	J	.81	.81	.81	1.00	1.00	1.00	1.00	1.25	1.25	1.25
	J	21	21	21	25	25	25	25	32	32	32
Diameter of stem	K	1.06	1.06	1.06	1.38	1.38	1.38	1.38	1.75	1.75	1.75
Diameter of Stem	K	27	27	27	35	35	35	35	44	44	44
Height of stem flats	L	.9	.9	.9	1.0	1.0	1.0	1.0	1.3	1.3	1.3
Height of Stein hats		23	23	23	25	25	25	25	33	33	33
Extreme width of body,	М	2.6	2.6	2.6	3.2	3.2	3.2	3.2	4.0	4.8	
Figure 142	IVI	66	66	66	81	81	81	81	102	122	
Diameter of hub,	N	2.3	2.3	2.3	2.9	2.9	3.6	4.3	5.2	6.4	
Figure 142	igure 142	58	58	58	74	74	91	109	132	163	
Size of Sealant Stick	ı	В	В	В	В	В	В	В	В	В	В
Size of wrench	_	SN-1	SN-1	SN-1	SN-2	SN-2	SN-2	SN-2	SN-4*	SN-4*	SN-4*
Length of wrench	_	7.0	7.0	7.0	10.5	10.5	10.5	10.5	17.5	15.0	15.0
		178	178	178	267	267	267	267	445	381	381
Weight (approx.), Figure 142	_	6	6	6	9	9	13	17	29	48	
		3	3	3	4	4	6	8	13	22	
Weight (approx.), Figure 143				9	14	14	20	25	38	65	80
	_			4	6	6	9	11	17	29	36

Flanges are drilled to ASME Class 125 Cast Iron Flange Standard Template. For drilling and bolting data, see page 45.

Figures 142 and 143 valves conform to the following standards where applicable: ASME B1.20.1; ASME B16.1; ASME B16.10; API 5B; ASTM A126, Class B; and MSS SP-78. See page 38.

Figure 143 face-to-face lengths are interchangeable with ASME Class 125 and API 175 CWP Cast Iron Gate Valves.

Figures 142 and 143 valves Size 5 (125 mm) and smaller are not recommended for temperatures above +200°F (+93°C).


^{*} Use the longer SN-3 wrench for valves used in cold climates such as Canada.


Nordstrom Bolted Gland-Type Iron Plug Valves

Short Pattern (Gate Length)

200 CWP (13.8 bar) 400 psig (27.6 bar) Test

Figure 143 Flanged, Wrench Operated, Sizes 6, 8 and 10





Size	NPS	6	8	10
Size	DN	150	200	250
Face-to-face, flanged, Figure 143	В	10.50	11.50	13.00
		267	292	330
Diameter of flange	С	11.0	13.5	16.0
		279	343	406
Thickness of flange	D	1.06	1.19	1.25
		27	30	32
Number and size of tapped holes in each flange*	_	two ¾"	two ¾"	two 7/8"
Center to top of stem	E	9.6	11.9	14.2
		244	302	361
Center to bottom of body	F	5.4	7.1	9.2
		137	180	234
Clearance required to remove sealant fitting	G	13.6	16.9	19.2
		345	429	488
Width of stem square	J	1.75	2.00	2.00
		44	51	51
Height of stem square	L	1.8	2.0	2.1
		46	51	53
Size of wrench	_	P-2	T-2	T-2
Length of wrench	_	27.0	36.0	36.0
		686	914	914
Size of sealant stick	_	D	G	G
Weight (approx.),	_	137	230	356
Figure 143		62	104	161

Flanges are drilled to ASME Class 125 Cast Iron Flange Standard Template. For drilling and bolting data, see page 45.

Figure 143 valves conform to the following standards where applicable: ASME B16.1; ASME B16.10; ASTM A126, Class B; and MSS SP-78. See page 38.

Figure 143 face-to-face lengths are interchangeable with ASME Class 125 and API 175 CWP Cast Iron Gate Valves.

*Note: Studs or capscrews required. For sizes and lengths, see page 48.