



- OPERATION INSTRUCTIONS**
- CONNECT THE PRECHARGE SUPPLY TO THE PRECHARGE ISOLATION VALVE.**
 - OPEN THE PRECHARGE ISOLATION VALVE TO ALLOW PRESSURE INTO THE REGULATOR.**
 - ONCE PRECHARGE PRESSURE GAUGE INDICATES DESIRED PSI, CLOSE THE ISOLATION VALVE.**
 - CONNECT THE TUBING FROM THE ODORIZATION SYSTEM TO THE REGULATOR INLET PORT.**
 - CONNECT THE TUBING TO THE INJECTION POINT TO THE REGULATOR OUTLET PORT.**

REMOVE ALL SHARP EDGES AND BURRS.

 201 IVYLAND RD IVYLAND, PA 18974		DRAWING NO: 59207 R 00	
		PART NO: 59207	
DESCRIPTION BACK PRESS REG ASSY, AL 100-2000 PSI CONTROL RANGE		SCALE: NTS	
		SHEET 1 OF 1	A SIZE
THIS DRAWING, AND ALL INFORMATION CONTAINED HEREIN REMAINS THE PROPERTY OF YZ SYSTEMS, INC. ALL RIGHTS ARE EXPRESSLY RESERVED AND MAY NOT BE REPRODUCED IN WHOLE OR IN PART WITHOUT YZ SYSTEMS, INC. WRITTEN CONSENT.		DRAWN: <i>JLB</i> DATE: 08/12/15	
TOLERANCE UNLESS OTHERWISE SPECIFIED		CHECKED: DATE:	
ANGULAR	FRACT.	DECIMAL	APPROVED: DATE:
± 1/2'	± 1/64	.XX = ±.01 .XXX = ±.005	